

Herewith is granted the right to the company

Ziehl-Abegg SE

in

D-74653 Künzelsau

for the operated fan test rig of **test category H** according to test and certification program TÜV SÜD Industrie Service GmbH for fan test rigs version 3/2015-08

located in

D-74653 Künzelsau

"LMS-3 Kammer-Prüfstand"

for the volumetric flow range of 630 m³/h to 28,000 m³/h and a pressure range up to 1,600 Pa,

based on the positive results of the completed Tests regarding compliance with the requirements of the Standard

DIN EN ISO 5801:2018-04

to identify this with the following TÜV SÜD Certification Mark.



This certificate is valid until 2023-06-30

Certificate Registration Number: 09/11/05



Certification Body for products
Refrigeration and air-conditioning
Munich, 2021-06-07



